

LPCB

This is to Certify

Context Plus Ltd

Export House, 175 Mauldeth Road, Fallowfield, Manchester,
M14 6SG, UK

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

EP203/CON Conventional three zone “class A” extinguisher control panel

which has complied with the requirements of the following:

EN 12094-1: 2003

EN 54-2: 1997 + A1: 2006 + A2: 2007

EN 54-4: 1997 + A1: 2002 + A2: 2006

Certificate No: 176c-(cl-2)

Issue Number: 01

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through
annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 176c-(cl-2)

Context Plus Ltd

Certified Products

LPCB Ref. No.

EP203/CON Conventional three zone "class A" extinguisher control panel under Context Plus Brand 176c/01

Incorporating the following units:

SPF0000203 Main extinguisher control
SPF0000212 External relay interface
SPF0003613 Power supply unit
SPF0000214 EP214 terminator

Incorporating as modular units:

EP210S Remote Status Unit "Surface Mount" optional (See Note 1)
EP211 Economy Status Unit optional (See Note 1)

Certified with the following options with requirements from EN 12094-1:2003

4.17 Delay of extinguishing signal
4.18 Signal representing the flow of extinguishing agent
4.19 Monitoring of the status of components
4.20 Emergency hold device
4.21 Control of flooding time
4.23 Manual only mode
4.26 Triggering of equipment outside the system
4.27 Emergency abort device
4.30 Activation of alarm devices with different signals

Appendix Issue No: 01

Page: 2 of 3

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 176c-(cl-2)

Context Plus Ltd

Certified with the following options with requirements from EN 54-2:1997

7.8	Output to fire alarm device(s)
7.11	Delays to the auctioning of outputs fire alarm devices and fire routing equipment
7.13	Alarm counter
10	Test condition

Note:

- 1) Optional Remote Status Unit part No. EP210S & Economy Status Unit part No. EP211 are not certified meeting the requirements of the standards specified
- 2) Meets the requirements of EN12094-3:2003, Class A – i.e. operational temperature range of -5°C to +40°C.

Appendix Issue No: 01

Page: 3 of 3

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.