



The mentioned product
complies with the
mentioned test
requirement

Intertek LSS Scheme Interim Tick Mark Certificate

15LHK0955-02

In accordance with the Tick Mark Rules and Certification System 5,
as defined in ISO / IEC 17067:2013, we certify that the product(s)

Context Plus ZFP Range of Control and Indicating Equipment

is in conformity with the following standard(s):

EN54-2:1997+A1:2006, EN54-4:1997+A1:2002+A2:2006

Report Number(s):
101237162LHD-001

Context Plus Limited

Export House, 175 Mauldeth Road, Fallowfield, Manchester, M14 6SG, United Kingdom

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the
above mentioned product(s)

This certificate is valid until:
2 March 2020

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	
No limitations apply	Certification Body: ITCL LSS Reference: LSS 0497 Issued Date: 2 September 2019

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Anees Vaheed





Intertek LSS Scheme Interim Tick Mark Certificate

15LHK0955-02

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

The optional features of the specifications that are included in the product and test report:

7.8	Output to fire alarm devices
7.11	Delays to outputs
7.12	Dependencies on more than one alarm signal
7.13	Alarm counter
8.3	Fault signals from points
9.5	Disabling of addressable points
10	Test condition

Brand and Model	Description	Factory Code
Z013040NS/X/CON	1 Loop Fire Alarm Control Panel	CTECUK.01
Z023040NS/X/CON	2 Loop Fire Alarm Control Panel	CTECUK.01
Z043040NS/X/CON	4 Loop Fire Alarm Control Panel	CTECUK.01



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Interim Tick Mark Certificate 15LHK0955-02

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 2

Products compliant with EN54-2:1997+A1:2006:

Brand and Model	Description
Z013040NS/X/CON	1 Loop Fire Alarm Control Panel
Z023040NS/X/CON	2 Loop Fire Alarm Control Panel
Z043040NS/X/CON	4 Loop Fire Alarm Control Panel

Product variants:

Variant	Description
Z013040NS/X/CON	1 Loop Fire Alarm Control Panel Comprising: Z41 Control Module, c/w touchscreen, access key switch and 16 LEDs (5 keyswitches) Z48 40-Zone Indicator Module BF362-5 Power Supply (Fitted within the CIE enclosure) Optional: Z11 4 Relay PCB Z12 8 Relay PCB Z13 8-I/O PCB Z14 16-I/O PCB

Variant	Description
Z023040NS/X/CON	2 Loop Fire Alarm Control Panel Comprising: Z41 Control Module, c/w touchscreen, access key switch and 16 LEDs (5 keyswitches) Z48 40-Zone Indicator Module BF362-5 Power Supply (Fitted within the CIE enclosure) Optional: Z11 4 Relay PCB Z12 8 Relay PCB Z13 8-I/O PCB Z14 16-I/O PCB



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Interim Tick Mark Certificate 15LHK0955-02

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 2 (Continued)

Variant

Z043040NS/X/CON

Description

4 Loop Fire Alarm Control Panel

Comprising:

Z41 Control Module, c/w touchscreen, access key switch and 16 LEDs (5 keyswitches)
Z48 40-Zone Indicator Module
BF362-5 Power Supply (Fitted within the CIE enclosure)

Optional:

Z11 4 Relay PCB
Z12 8 Relay PCB
Z13 8-I/O PCB
Z14 16-I/O PCB

Conditions of use:

ZFP range of models and variants listed in this certificate are suitable for indoor applications only.

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.